

BBA **BRITISH BOARD OF AGREEMENT**
TECHNICAL APPROVALS FOR CONSTRUCTION




Certificate **08/B052**

Norvik PVCu Window Systems Ltd
Mitchells Industrial Estate
Wombwell
Barnsley
South Yorkshire
S73 8HR

The above company's PVC-U windows have been assessed against the requirements of the British Fenestration Ratings Committee criteria for the energy rating of windows and achieved the following ratings:

Window system	Rating band	Rating value [kWhm ⁻² (year) ⁻¹]	U _{window} (Wm ⁻² K ⁻¹)	g _{window}	L _{factor} (Wm ⁻² K ⁻¹)
Duraflex Diamond Suite (65 mm) PVC-U Casement Diamant/Argon/Planitherm Total (Swisspacer 'V')	A	2	1.4	0.45	0.00
Duraflex Diamond Suite (70 mm) PVC-U Casement Diamant/Argon/Planitherm Total (Swisspacer 'V')	A	0	1.4	0.44	0.00
Duraflex Diamond Suite (65 mm) PVC-U Casement Optiwhite/Argon/K Glass (Swisspacer 'V')	B	-6	1.6	0.49	0.00
Duraflex Diamond Suite (70 mm) PVC-U Casement Optiwhite/Argon/K Glass (Aluminium spacer)	C	-19	1.8	0.49	0.00



Signed on behalf of the British Board of Agrément:

Date: 18th September 2008

This BFRC Certificate should not be confused with BBA Agrément Approval, details of which can be found on our website

British Board of Agrément, Bucknalls Lane, Garston, Watford, Hertfordshire WD25 9BA
Telephone: 01923 665300
Fax: 01923 665301

©2008

e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk